

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

**The Principal
K.C. Gurukul Public School
Opposite BSF Campus
Paloura, Jammu**

No: DFES-FP/9/2022-04(CC-7079422) / 1884


Dated: 25.10.2023

Sub: Provisional Fire Safety Certificate.

Ref: Your online application submission dated: 10.10.2023 (FI026-9067046).

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed 09 Nos. of First Aid Fire Extinguishers in their school premises but the Hose Reel Hose already recommended by this department not implemented by the management till date. However, the school is about 01 Km away from Fire and Emergency Station Canal (Lower Muthi) Jammu and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation provisionally subject to once again advised to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith:-

1. 06 Nos. of ABC Stored pressure Type Fire Extinguisher of 04 Kg capacity each should be provided at strategic locations of the school premises and 01 No. CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguisher.
2. Hose Reel Hoses as per BIS specifications connected with the terrace water tank of 5000 Ltrs. capacity should be provided in the school building. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of the school building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel Hoses.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. All electric installations existing in the building should be concealed conduit type.
5. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of fire fighting system installed in the school building.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
9. At present school is double storey. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
10. The department can make a surprise visit to your school at any time. During the visit if the first aid fire fighting system already installed in the school found defunct and deviation, this provisional clearance issued shall be treated automatically withdrawn/cancelled.
11. This provisional clearance shall be subject to outcome of any dispute/investigation/enquiry/trial if any, pending before any Court of Law/investigation agency. This provisional clearance shall not confirm any title upon the person/company in whose favour it is issued.
12. The validity of this provisional clearance shall remain in force for six months and same needs to be renewed after checking of entire fire fighting system (i.e. existing as well as proposed) installed in the school building. However, before granting permission/recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


Director
Fire & Emergency Services, J&K
Jammu/Srinagar